



24-XP31	K1202-2-1	27
24-XP32	K1202-2-3	28
24-XP4-1		29
24-XP4-2		30
24-XP5-1		31
24-XP5-2		32
25-XP21	K902-2-1	33
25-XP22	K902-2-3	34
25-XP31	K1102-2-1	35
25-XP32	K1102-2-3	36
25-XP4-1	K1002-2-1	37
25-XP4-2	K1002-2-3	38
25-XP5-1	K1202-2-1	39
25-XP5-2	K1202-2-3	40
26-XP21		41
26-XP22		42
26-XP31		43
26-XP32		44
26-XP4-1		45
26-XP4-2		46
26-XP5-1		47
26-XP5-2		48
		49
		50

34-XP21	K204-3-1	1
34-XP22	K204-3-2	2
34-XP31	K404-3-1	3
34-XP32	K404-3-2	4
34-XP4-1	K1504-3-1	5
34-XP4-2	K1504-3-2	6
34-XP5-1	K1503-3-1	7
34-XP5-2	K1503-3-2	8
35-XP21	4K1204-3-1	9
35-XP22	4K1204-3-2	10
35-XP31	6K1204-3-1	11
35-XP32	6K1204-3-2	12
35-XP4-1	K1204-3-1	13
35-XP4-2	K1204-3-2	14
35-XP5-1	5K1204-3-1	15
35-XP5-2	5K1204-3-2	16
36-XP21	2K1202-3-1	17
36-XP22	2K1202-3-2	18
36-XP31	K102-3-1	19
36-XP32	K102-3-3	20
36-XP4-1	1K10202-3-1	21
36-XP4-2	1K10202-3-3	22
36-XP5-1	12K10202-3-1	23
36-XP5-2	12K10202-3-3	24
37-XP21	K1102-3-1	25
37-XP22	2K1102-3-3	26
37-XP31	K1202-3-1	27
37-XP32	K1202-3-3	28
37-XP4-1		29
37-XP4-2		30
37-XP5-1		31
37-XP5-2		32
38-XP21	K902-3-1	33
38-XP22	K902-3-3	34
38-XP31	K1102-3-1	35
38-XP32	K1102-3-3	36
38-XP4-1	K1002-3-1	37
38-XP4-2	K1002-3-3	38
38-XP5-1	K1202-3-1	39
38-XP5-2	K1202-3-3	40
39-XP21		41
39-XP22		42
39-XP31		43
39-XP32		44
39-XP4-1		45
39-XP4-2		46
39-XP5-1		47
39-XP5-2		48
		49
		50

43-XP21	K104-M1-1	1
43-XP22	K104-M1-2	2
43-XP31	K104-M2-1	3
43-XP32	K104-M2-2	4
43-XP4-1	2K104-M1-1	5
43-XP4-2	2K104-M1-2	6
43-XP5-1	2K104-M2-1	7
43-XP5-2	2K104-M2-2	8
44-XP21	K102-1	9
44-XP22	K102-3	10
44-XP31	2K102-1	11
44-XP32	2K102-3	12
44-XP4-1		13
44-XP4-2		14
44-XP5-1		15
44-XP5-2		16
		17
		18
		19
		20

43-XP21	K104-M1-1	1
43-XP22	K104-M1-2	2
43-XP31	K104-M2-1	3
43-XP32	K104-M2-2	4
43-XP4-1	2K104-M1-1	5
43-XP4-2	2K104-M1-2	6
43-XP5-1	2K104-M2-1	7
43-XP5-2	2K104-M2-2	8
44-XP21	K102-1	9
44-XP22	K102-3	10
44-XP31	2K102-1	11
44-XP32	2K102-3	12
44-XP4-1		13
44-XP4-2		14
44-XP5-1		15
44-XP5-2		16
		17
		18
		19
		20

1. Монтаж выполнить проводами ПВ-3-660 сеч. 10 кв. мм ГОСТ 6323-79.
2. Цепи ~220 В (питающие линии от автоматов) проложить отдельно от низковольтных цепей питания 24 В.

